

## KEROSENE

	Unit	MIN	MAX	Test method
Appearance		Clear and bright		Visual
Density at 15°C	kg/m <sup>3</sup>	750,0	840,0	EN ISO 3675
Flash Point	°C	38,0	-	EN ISO 2719
Sulphur	mg/kg	-	1000	EN ISO 20846
Smoke Point	mm	-	19	BS 2000 -57
Char value	mg/kg	-	20	BS 2000 -10
Copper strip corrosion – (3 Hrs @ 50°C)	Rating	Class 1		EN ISO 2160
Viscosity at 40°C	mm <sup>2</sup> /s	1,00	2,00	EN ISO 3104
<b>Distillation:</b>				
% (V/V) recovered at 20 0°C	% V/V	15	-	EN ISO 3405
Final Boiling Point	°C	300	-	EN ISO 3405

## Notes:

1. This specification meets or exceeds BS 2869:2010 : Class C2

